

APPROVED TUBING

WARMBOARD COMFORT SYSTEM

These products are approved for panel projects **only** and are **not** to be used with the Warmboard Comfort System.

If equipment failure occurs on a WCS project that has not used the specified tubing, Warmboard has the option to deny any warranty claim related to the system hydronics.

PEX ALUMINUM PEX, 1/2" ID

- ▶ Warmboard PEX: PEX-AL-PEX
- ▶ Bluefin: PEX-AL-PEX
- ▶ Mr. Pex: PEX-AL-PEX
- ▶ Watts: PEX-AL-PEX

PEX, 1/2" ID

- ▶ HeatLink FL PEX-a
- ▶ Mr. Pex
- ▶ Rehau Raupex Oxygen Barrier
- ▶ Uponor helioPEX X2
- ▶ Uponor/Wirsbo hePEX
- ▶ ViegaPEX Barrier

Only use tubing listed here. Other products may create ticking noises during operation as the EVOH barrier rubs against the channel.

If using the Warmboard Comfort System, tubing and manifolds are included with the order and **do not** need to be purchased separately.

If only using Warmboard panels, tubing and manifolds may be purchased from us separately at very competitive prices.